

COMPLIANCE ASSISTANCE BULLETIN

News You Can Use

DEADLINE FOR INSTALLATION OF UNDER-DISPENSER CONTAINMENT FOR UNDERGROUND STORAGE TANK SYSTEMS

Purpose

The purpose of this Bulletin is to remind owners and operators of underground storage tanks (USTs) that the deadline to install under-dispenser containment (UDC) for their UST systems is rapidly approaching.

Issue

All UST systems are required to have UDC by December 31, 2003 (see Title 23, California Code of Regulations (CCR), Section 2636(h)) Approved UDC must be equipped with leak detection equipment and monitored in accordance with Title 23, CCR Section 2636(f).

What This Means To You

Owners or operators of an UST system must have their system fitted with UDC in accordance with the following schedule:

- At the time of installation for systems installed after January 1, 2000.
- By July 1, 2001 for systems installed after July 1, 1987 that are located within 1,000 feet of a public drinking water well.
- By December 31, 2003 for all other systems.

UDCs must be designed, constructed, installed and monitored in accordance with 23 CCR Section 2631, 2636(c)(2), 2636(e), and 2636(f).

Failure To Comply

Owners or operators who fail to install UDCs before the specified deadlines may be subject to enforcement action.

Continued on reverse

**For More
Information Or
Assistance**

If you need additional information or have questions concerning this Bulletin, contact Anthony Chu at (916) 875-8550.

**COUNTY OF SACRAMENTO
BOARD OF SUPERVISORS**

Roger Dickinson, 1st District
Illa Collin, 2nd District
Muriel P. Johnson, 3rd District
Roger Niello, 4th District
Don Nottoli, 5th District



Terry Schutten
County Executive

John O'Farrell, Administrator
Community Development &
Neighborhood Assistance Agency

Mel Knight, Director
Environmental Management
Department