

Septic System
Distance Requirements

<u>SEPTIC TANK TO:</u>	WATER WELLS	100'
	LAKE OR RESERVOIR	50'
	FLOWING STREAM	30'
	DRAINAGE OR EPHEMERAL STREAM	25'
	CUT OR FILL BANK	25'
	STRUCTURE	5'
	PROPERTY LINE	5'
	D-BOX	3'
	WATER LINES	10'
	(laterally)	1'
	(above pipe)	

TANK SHALL BE LEVEL

<u>D-BOX TO:</u>	PROPERTY LINES	10'
	BUILDINGS	5'
	SEPTIC TANK OR LEACHING PIT	3'

D-BOX SHALL BE LEVEL [Sec. VII (B)(2)(a)]
12"x 12" w/ 3" min. liquid depth [Sec. VII (B)(2)(b)]

<u>LEACH PITS TO:</u>	LAKE OR RESERVOIR	200'
	WATER WELLS	150'
	FLOWING STREAM	50'
	DRAINAGE OR EPHEMERAL STREAM	25'
	CUT OR FILL BANK	25'
	SIDEWALLS OF PITS	16'
	PIT BOTTOM TO GROUND WATER	10'
	WATER LINES	10'
		(laterally)
	(above pipe)	

3' MINIMUM DIAMETER (UNLESS OTHERWISE SPECIFIED; OR IF < 30' DEEP, 4' DIAMETER OR ADD ADDITIONAL 3' PIT)

INSPECTION PORT MINIMUM 12" OVERLAP OF LID ON TOP OF PIT \geq 1"

Septic System
Distance Requirements

<u>LEACH LINE TO:</u>	LAKE OR RESERVOIR	100'
	PUBLIC WELLS	100'
	PRIVATE WELLS	100'
	FLOWING STREAM	30'
	DRAINAGE OR EPHEMERAL STREAM	25'
	CUT OR FILL BANK	25'
	STRUCTURE	10'
	LEACH LINE (ON CENTER)	10'
	PROPERTY LINE	5'
	WATER LINES	10'
		(laterally)
	1'	
	(above pipe)	

MINIMUM WIDTH = 18"
MINIMUM DEPTH = 2'
MAXIMUM DEPTH = 3'

SOIL BACK FILL:
MINIMUM = 6"
MAXIMUM = 18"

<u>LEACH TRENCH TO:</u>	LAKE OR RESERVOIR	200'
	WATER WELLS	100'
	FLOWING STREAM	30'
	DRAINAGE OR EPHEMERAL STREAM	25'
	CUT OR FILL BANK	25'
	STRUCTURES	10'
	TRENCHES ON CENTER	10'
	TRENCH BOTTOM TO GROUND WATER	
		< 15' DEEP 5'
		> 15' DEEP 10'
	WATER LINES	10'
	(laterally)	
	1'	
	(above pipe)	

MINIMUM WIDTH = 18"