

| | | Pre June 2012 | Post June 2012 | LAMP Requirements |
|---|--|---|-----------------------------------|-------------------|
| SEPTIC TANK, PUMP TANK, Aerobic Treatment Unit | TO: WATER WELL | 100' | 100' | |
| | LAKE OR RESERVOIR | 50' | 50' | |
| | FLOWING STREAM OR CREEK | 30' | 50' | |
| | PONDS ³ | ---- | 50' | |
| | DRAINAGE COURSE OR EPHEMERAL STREAM | 25' | 50' | |
| | CURTAIN DRAINS - VERTICAL CURTAIN DRAINS | | | |
| | UP-GRADIENT | ---- | 20' | |
| | DOWN-GRADIENT | ---- | 25' | |
| | CUT OR FILL BANK (IN EXCESS OF 2.5') | 25' | 20' | |
| | STRUCTURE ¹ | 5' | 5' | |
| | EASEMENT | ---- | CLEAR | |
| | PROPERTY LINE | 5' | 5' | |
| | D-BOX | 3' | 3' | |
| | WATER SUPPLY LINES | 10' laterally, 1' | | |
| ON-SITE DOMESTIC WATER SERVICE | above leach line | 5' (UPC) ² | | |
| LINE | | 10'(UPC) ² | | |
| PRESSURE PUBLIC WATER MAIN | | | | |
| LEVEE (TOE) – CCR TITLE 23 | 10' | 10' ⁴ | | |
| D-BOX | | | | |
| TO: PROPERTY LINES | 10' | 5' | | |
| BUILDINGS ¹ | 5' | 5' | | |
| SEPTIC TANK, PUMP TANK OR DISPOSAL FIELD | 3' | 3' | | |
| LEVEE (TOE) – CCR TITLE 23 | 10' | 10' ⁴ | | |
| DISPOSAL FIELD (PIT, LEACH LINE, TRENCH) | 3', ----, ---- | 3' | | |
| LEACH PITS | | | | |
| TO: WATER WELL (DOMESTIC AND PUBLIC) | 150' | 150' | | |
| WATER WELL - PUBLIC | | | 200'* | |
| PUBLIC WATER SURFACE WATER INTAKE | | | 1,200' and 400' High water mark** | |
| LAKE OR RESERVOIR | 200' | 200' | | |
| FLOWING STREAM OR CREEK | 50' | 100' | | |
| PONDS ³ | ---- | 100' | | |
| DRAINAGE COURSE OR EPHEMERAL STREAM | 25' | 50' | | |
| CURTAIN DRAINS - VERTICAL CURTAIN DRAINS | | | | |
| UP-GRADIENT | ---- | 20' | | |
| DOWN-GRADIENT | ---- | 50' | | |
| CUT OR FILL BANK (IN EXCESS OF 2.5') | 25' | 4 x the height of the bank, to a maximum of 50' | | |
| STRUCTURE ¹ | 10' | 5' | | |
| EASEMENT | ---- | CLEAR | | |
| PROPERTY LINE | 5' | 5' | | |

| | | | Pre June 2012 | Post June 2012 | LAMP Requirements |
|-----------------------|-----|--|-------------------|---|---|
| | | D-BOX | 3' | 3' | |
| | | SIDEWALLS OF PITS | 16' | 16' | |
| | | PIT BOTTOM TO GROUNDWATER | 10' | 10' | |
| | | WATER SUPPLY LINES | 10' laterally, 1' | | |
| | | ON-SITE DOMESTIC WATER SERVICE | above leach line | 5' (UPC) ² | |
| | | LINE | | 10' (UPC) ² | |
| | | PRESSURE PUBLIC WATER MAIN | | | |
| | | LEVEE (TOE) – CCR TITLE 23 | 10' | 10' ⁴ | |
| SHALLOW TRENCH | | | | | |
| | TO: | WATER WELL (DOMESTIC AND PUBLIC) | 100' | 100' | |
| | | WATER WELL-PUBLIC | | | 150' |
| | | PUBLIC WATER SURFACE WATER INTAKE | | | 1,200' and 400' High water mark** |
| | | LAKE OR RESERVOIR | 100' | 200' | |
| | | FLOWING STREAM OR CREEK | 30' | 100' | |
| | | PONDS ³ | ---- | 100' | |
| | | DRAINAGE OR EPHEMERAL STREAM | 25' | 50' | |
| | | CURTAIN DRAINS - VERTICAL CURTAIN DRAINS | | | |
| | | UP-GRADIENT | ---- | 20' | |
| | | DOWN-GRADIENT | ---- | 50' | |
| | | CUT OR FILL BANK | 25' | 4 x the height of the bank, to a maximum of 50' | |
| | | STRUCTURES ¹ | 10' | 5' | |
| | | EASEMENTS | ---- | CLEAR | |
| | | PROPERTY LINE | 5' | 5' | |
| | | D-BOX | ---- | 3' | |
| | | LEACH LINE ON CENTER | 10' | 10' | |
| SHALLOW TRENCH | | | | | |
| | TO: | TRENCH BOTTOM TO GROUND WATER | ---- | 5' | |
| | | WATER SUPPLY LINES | 10' laterally, 1' | | |
| | | ON-SITE DOMESTIC WATER SERVICE | above leach line | 5' (UPC) ² | |
| | | LINE | | 10' (UPC) ² | |
| | | PRESSURE PUBLIC WATER MAIN | | | |
| | | LEVEE (TOE) – CCR TITLE 23 | 10' | 10' ⁴ | |
| DEEP TRENCH | | | | | |
| | TO: | WATER WELL (DOMESTIC OR PUBLIC) | 100' | 150' | |
| | | WATER WELL - PUBLIC | | | 200' |
| | | PUBLIC WATER SURFACE WATER INTAKE | | | 1,200' and 400' from high water mark** |
| | | LAKE OR RESERVOIR | 200' | 200' | |

| | Pre June 2012 | Post June 2012 | LAMP Requirements |
|--|------------------------------------|---|-------------------|
| FLOWING STREAM OR CREEK | 30' | 100' | |
| PONDS ³ | ---- | 100' | |
| DRAINAGE OR EPHEMERAL STREAM | 25' | 50' | |
| CURTAIN DRAINS - VERTICAL CURTAIN DRAINS | | | |
| UP-GRADIENT | ---- | 20' | |
| DOWN-GRADIENT | ---- | 50' | |
| CUT OR FILL BANK | 25' | 4 x the height of the bank, to a maximum of 50' | |
| STRUCTURES ¹ | 10' | 5' | |
| EASEMENTS | ---- | CLEAR | |
| PROPERTY LINE | 5' | 5' | |
| D-BOX | ---- | 3' | |
| TRENCHES ON CENTER | 10' | 10' | |
| TRENCH BOTTOM TO GROUNDWATER | | | |
| <15' DEEP | 5' | 5' | |
| >15' DEEP | 10' | 5' | |
| WATER SUPPLY LINES | 10' laterally, 1' above leach line | | |
| ON-SITE DOMESTIC WATER SERVICE LINE | | 5' (UPC) ² | |
| PRESSURE PUBLIC WATER MAIN | | 10' (UPC) ² | |
| LEVEE (TOE) – CCR TITLE 23 | 10' | 10' ⁴ | |

*Setbacks to public water wells less than 600 ft and greater than 20 ft in depth requires a 2-year travel time for microbiological contaminants shall be evaluated.

** If located 1,200 to 2,500 ft the dispersal field can be reduced to 200 ft from the high water mark.

1. Includes foundation lines for any structure including garages, out-buildings, in-ground swimming pools, porches, steps, breezeways, etc. (SCC 6.32, 2010 UPC).
2. Setback is for parallel construction. EMD approval required when crossing lines (1' above may be option).
3. Ponds less than 5000 gallons exempt from setback.
4. Verify setback requirement with applicable reclamation district